



From

Executive Engineer,
Provincial Division No.2,
PWD B&R Br., Rohtak.

To

The Chairman,
Zad Global School,
VPO Bhagwatipur, Tehsil Meham,
District Rohtak (Haryana).

Memo No. 9047

Dated 03/07/2018

Subject: - Issue of certificate regarding Structurally safe building of Zad Global School, VPO Bhagwatipur, Tehsil Meham in Rohtak District.


Reference:- Your office letter dated 29.06.2018.

In this connection it is submitted that after visual inspection by the SDE incharge alongwith concerned J.E. of the above school building at village Bhagwatipur Tehsil Meham in Distt. Rohtak found facts as under:


1. Building has been constructed in year 2013 (as per statement provided by you).
2. Plinth level is about 3" above road level.
3. There is no crack visible in existing building.
4. Construction of building is frame type structure.

Hence it is certified that the school building is seems to be structurally safe.

DA/- Nil


Executive Engineer,
Provincial Division No.2,
PWD B&R Branch Rohtak.

For ZAD EDUCATION SOCIETY


President